

# FIRE PROTECTION SYMBOLS

APPENDIX D-1

FILE NAME	SYMBOL	DESCRIPTION	FILE NAME	SYMBOL	DESCRIPTION	FILE NAME	SYMBOL	DESCRIPTION
F001		CHECK VALVE	F038		3 HOUR FIRE RATED	F068		DETECTOR, HEAT, RATE OF RISE
F002		SPRINKLER RISER	F037		3 HOUR FIRE RATED/ SMOKE BARRIER	F069		DETECTOR, IONIZATION SMOKE
F003		INDICATING VALVE	F03B		4 HOUR FIRE RATED	F070		DETECTOR, PHOTOELECTRIC SMOKE
F004		FIRE DEPARTMENT CONNECTION FREE STANDING	F039		4 HOUR FIRE RATED/ SMOKE BARRIER	F071		DETECTOR, SMOKE
F005		FIRE DEPARTMENT CONNECTION	F040		FIRE ALARM COMMUNICATOR	F072		DETECTOR, SWITCH LEVEL
F006		FIRE HYDRANT - TWO HOSE OUTLET	F041		MASTER FIRE ALARM CONTROL PANEL	F073		SPRINKLER HEAD SIDE WALL PENDANT
F007		FIRE HYDRANT - ONE HOSE OUTLET	F042		ALARM BOX	F074		SPRINKLER HEAD SIDE WALL PENDANT
F008		FIRE HYDRANT - TWO HOSE OUTLET & PUMPER CONN.	F043		ALARM GONG	F075		SPRINKLER HEAD SIDE WALL PENDANT
F009		WALL HYDRANT - TWO HOSE OUTLET	F044		ALARM, VOICE COMMUNICATION PANEL	F076		DETECTOR SWITCH, DAMPER POSITION
F010		WATER SYSTEM BLOCK VALVE	F045		ALARM, TAMPER SWITCH	F077		FIRE SUPPRESSION, BUTTERFLY VALVE, INDICATING
F011		PRESSURE REDUCING VALVE	F046		FIRE ALARM STATION MANUAL PULL	F078		FIRE SUPPRESSION, EXTINGUISHER CO <sub>2</sub> AUTOMATIC ACTUATED
F012		REDUCER	F047		FIRE SUPPRESSION PRESSURE SWITCH	F079		FIRE SUPPRESSION, EXTINGUISHER CARBON DIOXIDE SYSTEM
F013		DRY CHEMICAL SUPPRESSION SYSTEM	F048		DETECTION, FIRE ALARM ANNUCIATOR PANEL	F080		FIRE PROTECTION, MANUAL CARBON DIOXIDE STATION
F024		KEY BOX	F049		SPRINKLER HEAD SIDE WALL PENDANT	F081		FIRE SUPPRESSION, REEL CARBON DIOXIDE STATION
F015		POST INDICATOR VALE	F050		SPRINKLER HEAD SIDE WALL UPWRIGHT	F082		FIRE SUPPRESSION, AUTOMATIC ACTUATED HALON
F016		DETECTION, SMOKE CONTROL PRESSURE PANEL	F051		SPRINKLER HEAD PENDENT	F083		FIRE SUPPRESSION, HALON EXTINGUISHER
F017		FIRE PROTECTION INDICATING VALVE NUMBER	F052		SPRINKLER HEAD UPWRIGHT	F084		FIRE SUPPRESSION, HALON MANUALLY ACTUATED EXTINGUISHER
F018		BLOCK VALVE NUMBER - FIRE HYDRANT NUMBER	F053		PRESSURE SWITCH DETECTOR	F085		FIRE SUPPRESSION, HALON SYSTEM
F019		WATER SYSTEM BLOCK VALVE NUMBER	F054		FLOW SWITCH	F086		FIRE SUPPRESSION, MANUAL WET CHEMICAL STATION
F020		BUILDING FIRE ALARM CONTROL PANEL	F055		ALARM, HORN/LIGHT, ONE ASSEMBLY	F087		FIRE SUPPRESSION, MANUAL STATION
F021		CARBON DIOXIDE SUPPRESSION SYSTEM	F056		ALARM, HORN/LIGHT, SEPARATE ASSEMBLY	F088		FIRE SUPPRESSION, WET CHEMICAL SYSTEM
F022		HALON CONTROL PANEL	F057		ALARM, LAMP/LIGHT, SIGNAL LIGHT STROBE	F089		FIRE SUPPRESSION, DRY CHEMICAL SYSTEM
F023		FIRE SYSTEM ANNUNCIATOR	F058		ALARM, MANUAL CONTROL	F090		FIRE SUPPRESSION, EXTINGUISHER DRY CHEMICAL
F024		FIRE ALARM TRANSMITTER	F059		ALARM, MINI HORN	F091		FIRE SUPPRESSION, EXTINGUISHER DRY CHEMICAL STATION REEL
F025		ELEVATOR STATUS/RECALL	F060		ALARM, SPRINKLER SYSTEM FLOW BELL	F092		FIRE SUPPRESSION, EXTINGUISHER MANUALLY ACTUATED DRY CHEMICAL
F026		CONTROL PANEL FOR HEATING, VENTILATION, AIR-CONDITIONING, EXHAUST STAIRWELL PRESSURIZATION, OR SIMILAR EQUIPMENT.	F061		FIRE SUPPRESSION, FIRE DEPARTMENT KEY LOCK	F093		FIRE DEPARTMENT CONNECTION, ONE-WAY
F027		SMOKE BARRIER	F062		DETECTION SWITCH, ABORT	F094		FIRE SUPPRESSION, FIRE HOSE CONNECTION, INSPECTOR'S TEST
F028		1/2 HOUR FIRE RATED	F063		DETECTOR, FLAME FLICKER			
F029		1/2 HOUR FIRE RATED/ SMOKE BARRIER	F064		DETECTOR, HEAT			
F030		3/4 HOUR FIRE RATED	F065		DETECTOR, HEAT COMBINATION			
F031		3/4 HOUR FIRE RATED/ SMOKE BARRIER	F066		DETECTOR, HEAT, FIXED TEMPERATURE			
F032		1 HOUR FIRE RATED	F067		DETECTOR, HEAT, RATE COMPENSATION			
F033		1 HOUR FIRE RATED/ SMOKE BARRIER						
F034		2 HOUR FIRE RATED						
F035		2 HOUR FIRE RATED/ SMOKE BARRIER						